





GOVERNMENT OF TAMILNADU DEPARTMENT OF PUBLIC HEALTH & PREVENTIVE MEDICINE 6A.SANITARY CERTIFICATE

THE TAMILNADU EDUCATIONAL RULE 24 & APPENDIX-3

DISTRICT : VILLUPURAM	TALUK : Gingee
Certificate No: 00 1245/33/2024	BLOCK : Ginges

I hereby declare that I have inspected Sxi Saixam Public School
Jayankondan Village Gingee Block & Taluk
Jayankondan Village, Gingee Block & Taluk Villufikam District -604 202.
on 27.02.2024 which requires the Sanitary Certificate for the year of

CERTIFIED:

- .That the accommodation provided for each of the several classes is sufficient for the minimum number of pupils taught there in is properly ventilated and lighted
- . That the building is maintained properly in substaintial repair.
- . That it is neat and clean.
- . That the latrine arrangements are adequate and satisfactory.
- . That the supply of drinking water is wholesome and that in all other aspects of sanitation is GOOD.
- . Hence this certificate is issued subject to the conditions.
- 1. Under COTPA Act 2003 and Rules-2008 display sign boards should be fixed Insdie the institution at various locations.
- 2. This certificate is valid for one Year from the Date of issue.

. There after it will be renewed by the School /College Management

Block Health Supervisor, Govt.Primary Health Centre,

Date: .03.2024 Sathiyamangalam. Place: Sathiyamangalam.

Villupuram District.

Countersigned: Based on Block Health Supervisor's Inspection Report.

As per L.Dis.No: 001245 /33/2024 Dated:01-03-2024 of DDHS Villupuram

SRISAIRAM

Deputy Director of Health Services.

Willupuram.

lo.3, 18t Floor, Villepuram Road Gingel-GA 202 VPM Dist CHAIRMAN

TEST WATER BEFORE TASTE



TAMILNADU WATER SUPPLY AND DRAINAGE BORD

District level Water Testing Laboratory

TWAD Board, Near New Veeranam illam, GST Road, Thindivanam - 604 002

TEST REPORT E-mail: jwalabtdm@dataone.in JPh: 04147 - 22730

From, K. Ananthi M.Sc, Junior Water Analyst (a/c), District Water Testing Laboratory,

To Sri Sairam Public School (CBSE), Jamboothi Rettanai Road, Jayankondan Panchayat,

Tindivanam.

Lr.No. 625 / DWTL/TDM Date: 13 .02 .2024 Gingee Union

Sir,

Sub: Examination of water sample Report Furnished-Reg.

The Result of analysis for the water samples received vide ref cited is furnished below.

Date of Receipt: Date of Testing:	07.02.2024 07.02.2024	Sample I D No. 625	Union: Gingee Panchayat: Jayankondan Village: Jayankondan Types of Source: Open well Location: Sri Sairam Public School
District	Villupuram		
BIS 10500 : 2012 I.PHYSICAL EXAMINATION	Acceptable limit	Permissible limit in the absence of alternate source	Result
1. Appearance			Clear
2. Odour	Agreeable	Agreeable	None
3. Turbidity NT Units		5	0
4. Total dissolved Solids mg/L	500	2000	998
5. Electrical Conductivity Micro mho/cm			1426
II.CHEMICAL EXAMINATION:			
6. pH	6.5-8.5	6.5-8.5	7.28
7. Total Alkalinity. as CaCo _{3 mg/L}	200	600	288
8. Total Hardness as CaCo _{3 mg/L}	200	600	272
9. Calcium as Ca mg/L	75	200	86
10. Magnesium as Mg mg/L	30	100	45
11. Iron as Fe mg/L	0.3	0.3	0.0
12. Manganese mg/L	0.1	0.1	0.0
13. Free Ammonia as NH _{3 mg/L}	0.5	0.5	
14. Nitrite as NO _{2 mg/L}			•
15. Nitrate as NO3 mg/L	45	45	01
16. Chloride as Cl mg/L	250	1000	296
17. Fluoride as F mg/L	1.0	1.5	3. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1.
18. Sulphate as SO _{4 mg/L}	200	400	54
19. Phosphate as PO _{4 mg/L}		* * *	
20. Tidys Test 4 hrs.as O _{2 mg/L}			0.0
21.Free residual Chlorine (ppm)	0	0	0.0
III.BACTERIOLOGICALEXAMINATION [M.F. Technique]			
Fecal Coliform (100 ml)	0	0	480

Report: The given Water Sample is Physically, Chemically Potable and Bacteriologically is Non-Potable for Drinking purpose Proper Chlorination to be done @ the OHT.

13/2/24

For SRI SAIRAM PUBLIC SCHOOL

District Water Testing Liboratory,

CHAIRMAN

Tindivanam

SRI SAIRAM PUBLIC SCHOOL (CBSE)

JAYANKONDAN.